

# TEMPORARY ELECTRICAL INSTALLATION INSPECTION CHECKLIST

## GENERAL INFORMATION

Name: \_\_\_\_\_

Date: \_\_\_\_\_

Location: \_\_\_\_\_

## Power Supply & Distribution

Yes  No — Temporary power supply is installed by a qualified electrician

Yes  No — Power distribution boards are properly labeled and accessible

Yes  No — Protective devices (fuses, breakers, RCDs) are installed and functional

Yes  No — Power supply capacity is adequate for site requirements

## Wiring & Cabling

Yes  No — Cables are free from damage, cuts, or exposed conductors

Yes  No — Extension cords are rated for site use and properly grounded

Yes  No — Cables are routed to avoid tripping hazards and protected from damage

Yes  No — Connections and joints are secure and weather-protected

## **Grounding & Bonding**

- Yes  No — All equipment and panels are properly grounded
- Yes  No — Grounding rods or systems are installed and tested
- Yes  No — Bonding is provided between electrical enclosures and metal structures
- Yes  No — Ground fault protection devices are present and tested

## **Lighting & Fixtures**

- Yes  No — Temporary lighting is adequate for work areas and walkways
- Yes  No — Fixtures are securely mounted and weather-resistant
- Yes  No — Emergency and exit lighting is installed where required
- Yes  No — Lamps and fittings are free from cracks, breaks, or exposed wiring

## **Equipment & Tools**

- Yes  No — Portable electrical tools are tested and tagged as safe
- Yes  No — Double-insulated tools are used where appropriate
- Yes  No — Defective or damaged tools are removed from service immediately
- Yes  No — Lockout/Tagout procedures are followed when servicing equipment

## General Safety

- Yes  No — Electrical installations comply with local codes and standards
- Yes  No — Temporary installations are regularly inspected and maintained
- Yes  No — Warning signs and barriers are in place near electrical hazards
- Yes  No — Workers are trained in electrical safety and emergency response

## FINAL NOTES

Inspector Comments:

---

---

---

---

Inspector Name: \_\_\_\_\_

Inspector Email: \_\_\_\_\_

Inspection Date: \_\_\_\_\_

I confirm this inspection was completed accurately

Powered by:  FIELD EAGLE [www.fieldeagle.com](http://www.fieldeagle.com)