

# WORKSITE FIRE SAFETY INSPECTION CHECKLIST

## GENERAL INFORMATION

Name: \_\_\_\_\_

Date: \_\_\_\_\_

Location: \_\_\_\_\_

### Fire Extinguishers & Suppression Equipment

Yes  No — Fire extinguishers are present, charged, and easily accessible

Yes  No — Fire blankets and suppression systems are available where required

Yes  No — Fire extinguishers are inspected and tagged with current dates

### Emergency Exits & Evacuation Routes

Yes  No — Emergency exits are clearly marked and unobstructed

Yes  No — Evacuation routes are free from obstacles and well-lit

Yes  No — Exit signage is visible and compliant with regulations

### Fire Alarms & Detection Systems

Yes  No — Smoke detectors and fire alarms are functional and tested

Yes  No — Alarm signals are audible and/or visible throughout the site

Yes  No — Fire alarm control panels are accessible and operational

### **Flammable Materials Storage**

- Yes  No — Flammable liquids and gases are stored in approved containers
- Yes  No — Storage areas are well-ventilated and away from ignition sources
- Yes  No — Safety signage is displayed near hazardous storage areas

### **Hot Work & Ignition Control**

- Yes  No — Hot work permits are issued for welding, cutting, and grinding
- Yes  No — Fire watches are in place during hot work activities
- Yes  No — Combustible materials are removed or protected from ignition

### **Training & Safety Procedures**

- Yes  No — Workers are trained in fire safety and emergency response
- Yes  No — Fire drills are conducted regularly
- Yes  No — First aid kits and emergency communication devices are available

### **General Site Conditions**

- Yes  No — Housekeeping minimizes fire hazards (debris, waste, and combustible materials)
- Yes  No — Electrical installations do not present fire risks
- Yes  No — Smoking areas are designated and controlled

## FINAL NOTES

Inspector Comments:

---

---

---

---

Inspector Name: \_\_\_\_\_

Inspector Email: \_\_\_\_\_

Inspection Date: \_\_\_\_\_

I confirm this inspection was completed accurately

Powered by:  FIELD EAGLE [www.fieldeagle.com](http://www.fieldeagle.com)