

UNDERGROUND STORAGE TANK INSPECTION CHECKLIST

GENERAL INFORMATION

Name: _____

Date: _____

Location: _____

Site Access & Safety

- Yes No — Access manholes are secure and clearly marked
- Yes No — Spill buckets are clean and free of liquid
- Yes No — Overfill prevention devices are operational
- Yes No — Vent pipes are upright and unobstructed

Leak Detection Systems

- Yes No — Monitoring console is powered and active
- Yes No — No active alarms or warning lights visible
- Yes No — Sensors are correctly positioned in sumps
- Yes No — Release detection records are current

Containment Sumps

- Yes No — Sumps are dry and free of debris or fuel
- Yes No — Piping components show no signs of leaks

Yes No — Test boots are properly positioned

Yes No — Penetration fittings are tight and sealed

Corrosion Protection

Yes No — Rectifier is on and reading within range

Yes No — Metal components are free of severe rust

Yes No — Sacrificial anodes are functioning correctly

Yes No — 60-day inspection log is up to date

FINAL NOTES

Inspector Comments:

Inspector Name: _____

Inspector Email: _____

Inspection Date: _____

I confirm this inspection was completed accurately