

FIRE EXTINGUISHER INSPECTION CHECKLIST

GENERAL INFORMATION

Name: _____

Date: _____

Location: _____

Accessibility & Location

- Yes No — Extinguisher is in its designated place
- Yes No — Access is unobstructed and visible
- Yes No — Operating instructions are facing outward
- Yes No — Cabinet or bracket is securely mounted

Physical Condition

- Yes No — Safety seal and tamper indicator are intact
- Yes No — No physical damage, corrosion, or leakage
- Yes No — Hose and nozzle are free of obstructions
- Yes No — Pressure gauge reading is in the green zone

Labeling & Documentation

- Yes No — HMIS label is present and legible
- Yes No — Inspection tag is attached and current

Yes No — Maintenance records are up to date

Yes No — Classification markings are clearly visible

Weight & Operation

Yes No — Extinguisher feels full when lifted

Yes No — Pull pin functions correctly

Yes No — Handle and lever work smoothly

Yes No — Hydrostatic testing date is valid

FINAL NOTES

Inspector Comments:

Inspector Name: _____

Inspector Email: _____

Inspection Date: _____

I confirm this inspection was completed accurately