

FIRE SUPPRESSION SYSTEM INSPECTION (KITCHEN) CHECKLIST

GENERAL INFORMATION

Name: _____

Date: _____

Location: _____

Hood and Ductwork

- Yes No — Filters are clean and free of grease buildup
- Yes No — Hood interior is free from excessive grease
- Yes No — Ductwork access panels are secure and accessible
- Yes No — Exhaust fan is operating correctly

Nozzles and Caps

- Yes No — Nozzles are aimed correctly at appliances
- Yes No — Nozzles are free of grease and obstruction
- Yes No — Blow-off caps are present on all nozzles
- Yes No — Piping is secure and undamaged

Manual Pull Station

- Yes No — Pull station is unobstructed and visible
- Yes No — Safety pin and seal are intact

Yes No — Instructions are legible and clear

Yes No — Located within path of egress

Cylinder and Gauge

Yes No — Pressure gauge is in the green zone

Yes No — Inspection tag is current and punched

Yes No — Cylinder is securely mounted

Yes No — Hydrostatic test date is current

FINAL NOTES

Inspector Comments:

Inspector Name: _____

Inspector Email: _____

Inspection Date: _____

I confirm this inspection was completed accurately