

COMPRESSED AIR SYSTEM INSPECTION CHECKLIST

GENERAL INFORMATION

Name: _____

Date: _____

Location: _____

Compressor Unit

- Yes No — Compressor housing is free of damage and leaks
- Yes No — Oil levels are within manufacturer specifications
- Yes No — Drive belts are properly tensioned and intact
- Yes No — Cooling fans and vents are clean and unobstructed

Air Receivers & Tanks

- Yes No — Tank exterior is free of rust and corrosion
- Yes No — Pressure relief valves are tested and operational
- Yes No — Condensate drains are functioning properly
- Yes No — Pressure gauges are readable and accurate

Piping & Distribution

- Yes No — Air lines are securely mounted and supported
- Yes No — No audible air leaks detected along piping

Yes No — Valves and fittings are tight and undamaged

Yes No — Hoses are free of cracks, bulges, or wear

Air Treatment & Filters

Yes No — Intake filters are clean and properly installed

Yes No — Air dryers are operating at correct temperatures

Yes No — Line filters and separators are drained and clean

Yes No — Lubricators are filled and dispensing correctly

FINAL NOTES

Inspector Comments:

Inspector Name: _____

Inspector Email: _____

Inspection Date: _____

I confirm this inspection was completed accurately