

BOILER & STEAM SYSTEM INSPECTION CHECKLIST

GENERAL INFORMATION

Name: _____

Date: _____

Location: _____

Boiler Exterior

☐ Yes ☐ No — Casing is free of rust, dents, and leaks

☐ Yes ☐ No — Burner area is clean and unobstructed

☐ Yes ☐ No — Safety tags and labels are legible

☐ Yes ☐ No — Access doors open and close properly

Safety Devices

☐ Yes ☐ No — Pressure relief valve operates correctly

☐ Yes ☐ No — Low water cut-off trips as designed

☐ Yes ☐ No — Emergency shut-off is functional

☐ Yes ☐ No — Flame safeguard devices are intact

Controls & Instruments

☐ Yes ☐ No — Gauges read accurately within range

☐ Yes ☐ No — Thermostats and controllers respond promptly

☐ Yes ☐ No — Alarm signals are audible and visible

☐ Yes ☐ No — Wiring is secure with no signs of wear

Steam Piping

☐ Yes ☐ No — Insulation is intact and undamaged

☐ Yes ☐ No — Joints are tight, no steam leaks observed

☐ Yes ☐ No — Drains are operable and free of blockage

☐ Yes ☐ No — Supports and hangers are secure

☐ I confirm this inspection was completed accurately

Powered by:  FIELD EAGLE www.fieldeagle.com